



**BUREAU
VERITAS**

Certificate of compliance

Applicant: Hoymiles Power Electronics Inc.
No.18 Kangjing Road Hangzhou Zhejiang Province
P.R.China

Product: HiFlow Microinverter

Model: HF-800-WB

The device is designed to work as a generation unit of the type: A

Inverter for single phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019/A1:2023

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: BMH-ESH-P25071697

Certification Program: NSOP-0032-DEU-ZE-V10

Certificate number: U25-0713

Date of issue: 2025-07-30

Certification body

Accreditation



Domenik Koll
Head of Energy Systems Germany



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.



BUREAU
VERITAS

Annex certificate of conformity No. U25-0713

Extract from test report BMH-ESH-P25071697 issued by a testing laboratory accredited by "Deutsche Akkreditierungsstelle GmbH (DAkkS)" according to ISO/IEC 17025. The accreditation is only valid for the scope listed in the annex of the accreditation certificate "D-PL-12024-03-04".

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016

Manufacturer	Hoymiles Power Electronics Inc. No.18 Kangjing Road Hangzhou Zhejiang Province P.R.China			
Product type	HiFlow Microinverter			
Static converter model	HF-800-WB	--	--	--
Input DC (photovoltaic)				
MPP voltage range [V]	16-96	--	--	--
Max. input voltage [V]	100	--	--	--
Max. input current per MPPT [A]	16	--	--	--
Output AC				
Rated AC voltage [V]	230, L/N/PE, 50Hz	--	--	--
Rated output current [A]	3,48	--	--	--
Max. output current [A]	3,48	--	--	--
Nom. converter output (P_{NINV}) [W]	800	--	--	--
Rated apparent power [VA]	800	--	--	--



BUREAU
VERITAS

Annex certificate of conformity No. U25-0713

Extract from test report BMH-ESH-P25071697 issued by a testing laboratory accredited by "Deutsche Akkreditierungsstelle GmbH (DAkkS)" according to ISO/IEC 17025. The accreditation is only valid for the scope listed in the annex of the accreditation certificate "D-PL-12024-03-04".

Interface protection system and interface switch (Network and system protection "NS-protection")	
Type of protection	Integrated NS-protection
Assigned to generation unit type	HF-800-WB
Integrated interface switch	Type of switching equipment 1: galvanic separation HF-Transformer Type of switching equipment 2: Relay (Model RT2 DC)
	Note: The output is switched off by the inverter bridge and one relay in series in each line and neutral.
Firmware version	V1.08.00
Note The settings of the interface protection are password protected adjustable. In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration. The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.	



BUREAU
VERITAS

Annex certificate of conformity No. U25-0713

Extract from test report BMH-ESH-P25071697 issued by a testing laboratory accredited by "Deutsche Akkreditierungsstelle GmbH (DAKKS)" according to ISO/IEC 17025. The accreditation is only valid for the scope listed in the annex of the accreditation certificate "D-PL-12024-03-04".

Name of parameter set		EN 50549-10				
specific technical requirement (e.g. grid codes)		EN 50549-1&EN 50549-10				
Clause(s) / subclause(s) of EN 50549-1:2019	Parameter ^a	Remarks/ additional information ^b	Configurable value range	default value		
4.3.2	Interface switch		yes no	yes		
4.4.2	Operating frequency range					
	47,0 – 47,5 Hz Duration		0 – 20 s	0s		
	47,5 – 48,5 Hz Duration		30 – 90 min	30 min		
	48,5 – 49,0 Hz Duration		30 – 90 min	30 min		
	49,0 – 51,0 Hz Duration		not configurable	unlimited		
	51,0 – 51,5 Hz Duration		30 – 90 min	30 min		
4.4.3	Minimal requirement for active power delivery at underfrequency					
	Reduction threshold		not configurable	49,5 Hz		
4.4.4	Continuous operating voltage range					
	Upper limit		not configurable	110 % Un		
4.4.4	Continuous operating voltage range					
	Lower limit		not configurable	85 % Un		
4.5.2	Rate of change of frequency (ROCOF) immunity	ROCOF withstand capability (defined with a sliding measurement window of 500 ms) non-synchronous generating technology: synchronous generating technology:	not configurable	2 Hz/s		
4.5.3.2	Under-voltage ride through (UVRT) Generating plant with non-synchronous generating technology					
	Maximum power resumption time		not configurable	1 s		
	Voltage-Time-Diagram			see Figure 6 of EN 50549-1:2019	Time[s]	U[p.u.]
					0,00	0,20
					0,15	0,20
					1,50	0,85
					180	0,85
		Fast fault current		Rated value	HF-800-WB: 3,48 A (rated current)	
		Active power recovery after a short circuit		configurable	Start at 90% U _n	
		Fault recovery of active power (times calculated from the removal of the short circuit)		configurable	≤ 5 s	
	Value for recovered active power		configurable	≥ 90 %		
	Accuracy for recovery of active power		not configurable	≤ 10 %		
	Reactive power contribution has priority		yes no	Yes		
4.5.4	Over-voltage ride through (OVRT)		not configurable see Figure 8 of	Time[s] U[p.u.]		

Name of parameter set		EN 50549-10			
specific technical requirement (e.g. grid codes)		EN 50549-1&EN 50549-10			
Clause(s) / subclause(s) of EN 50549-1:2019	Parameter ^a	Remarks/ additional information ^b	Configurable value range	default value	
4.3.2 Interface switch	Single fault tolerance for interface switch		yes no	yes	
			EN 50549-1:2019	0,0	1,25
				0,1	1,25
				0,1	1,20
				5,0	1,20
				5,0	1,15
				60	1,15
				60	1,10
				Active power recovery after a short circuit	
	Fault recovery of active power (times calculated from the removal of the short circuit)		configurable	≤ 5 s	
	Value for recovered active power		configurable	≥ 90%	
Accuracy for recovery of active power		not configurable	≤ 10%		
4.6.1 Power response to overfrequency	Threshold frequency f ₁		50,2 Hz – 52 Hz	50,2 Hz	
	Droop		2 % – 12 %	5 %	
	Power reference		P _M P _{max}	P _M for other non-synchronous generating technology (inverter)	
	Intentional delay		0 – 2 s	0s	
	Deactivation threshold f _{stop}		50,0 Hz – f ₁	deactivated	
	Deactivation time t _{stop}		0 – 600 s	-	
	Acceptance of staged disconnection		yes no	yes	
4.6.2 Power response to underfrequency	Threshold frequency f ₁		49,8 Hz – 46 Hz	49,8 Hz	
	Droop		2 % – 12 %	5 %	
	Intentional delay		P _M P _{max}	P _{max}	
			0 – 2 s	0s	
4.7.2.2 voltage support by reactive power -Capabilities	Active factor / Reactive power (%Pd) range overexcited		0,90 – 1 / 48% P _d - 0 0,95 – 1 / 33% P _d - 0	0,80 – 1 / 66% P _d - 0	
	Active factor / Reactive power (%Pd) range underexcited		0,90 – 1 / 48% P _d - 0 0,95 – 1 / 33% P _d - 0	0,80 – 1 / 66% P _d - 0	
4.7.2.3 voltage support by reactive power - Control modes	Enabled control mode		Q setp. Q(U)	activated deactivated	

Name of parameter set		EN 50549-10		
specific technical requirement (e.g. grid codes)		EN 50549-1&EN 50549-10		
Clause(s) / subclause(s) of EN 50549-1:2019	Parameter ^a	Remarks/ additional information ^b	Configurable value range	default value
4.3.2 Interface switch	Single fault tolerance for interface switch		yes no	yes
			Q(P) cos φ setp. cos φ (P)	deactivated deactivated deactivated
4.7.2.3.2 voltage support by reactive power - Set point control modes	Q set point and excitation		0 – 48 % PD, 0 – 33 %PD	0
	cos φ set point and excitation		1 – 0,9	1
4.7.2.3.3 voltage support by reactive power - Voltage related control modes	Characteristic curve		cos φ (P) Q(P)	indicate default characteristic
	Time constant		3 s – 60 s	10 s
	Min cos φ		0,0 – 1	0,4
	Lock-in power		0 % – 20 %	deactivated
	Lock-out power		0 % – 20 %	deactivated
4.7.2.3.4 voltage support by reactive power - Power related control mode	Characteristic curve		Q(U) P(U)	Q(U) (single-phase inverter) 0,00...-0,6 0,92...-0,6 0,94...0,0 1,06...0,0 1,08...0,6 1,20...0,6 P(U) deactivated
4.7.4.2.2 Zero current mode for converter connected generating technology / Generating Plant with non-synchronous generator	Enabling		enable disable	disable
	Static voltage range overvoltage		100 % Un – 120 % Un	120 % Un
	Static voltage range undervoltage		20 % Un – 100 % Un	50 % Un
4.9.3 Requirements on voltage and frequency protection	Threshold for protection as dedicated device [in A or kW, kVA]		16 A – 250 kVA	Internal safety device
	Undervoltage threshold stage 1		0,2 Un – 1 Un	0,85 Un
	Undervoltage operate time stage 1		0,1 s – 100 s	10,0 s
	Undervoltage threshold stage 2		0,2 Un – 1 Un	0,50 Un
	Undervoltage operate time stage 2		0,1 s – 5 s	0,1 s
	Overvoltage threshold stage 1		1,0 Un – 1,2 Un	1,20 Un
	Overvoltage operate time stage 1		0,1 s – 100 s	10,0 s
	Overvoltage threshold stage 2		1,0 Un – 1,3 Un	1,25 Un
	Overvoltage operate time stage 2		0,1 s – 5 s	0,1 s

Name of parameter set		EN 50549-10		
specific technical requirement (e.g. grid codes)		EN 50549-1&EN 50549-10		
Clause(s) / subclause(s) of EN 50549-1:2019	Parameter ^a	Remarks/ additional information ^b	Configurable value range	default value
4.3.2 Interface switch	Single fault tolerance for interface switch		yes no	yes
	Overvoltage threshold 10 min mean protection		1,0 U _n – 1,15 U _n	1,10 U _n
	Overvoltage operate time 10 min mean protection		0,04 s – 10,00 s	10 min (update every 3s)
	Underfrequency threshold stage 1		47,0 Hz – 50,0 Hz	47,5 Hz
	Underfrequency operate time stage 1		0,1 s – 100 s	2,0 s
	Underfrequency threshold stage 2		47,0 Hz – 50,0 Hz	47,0 Hz
	Underfrequency operate time stage 2		0,1 s – 5 s	0,1 s
	Overfrequency threshold stage 1		50,0 Hz – 52,0 Hz	51,5 Hz
	Overfrequency operate time stage 1		0,1 s – 100 s	2,0 s
	Overfrequency threshold stage 2		50,0 Hz – 52,0 Hz	52,0 Hz
	Overfrequency operate time stage 2		0,1 s – 5 s	0,1 s
	Loss of mains according EN 62116 (LoM)		0 s – 6000 s	ROCOF 2,0 Hz/s (0,5 s) active 2 s (5 s)
	4.10.2 Automatic reconnection after tripping	Lower frequency		47,0 Hz – 50,0 Hz
Upper frequency			50,0 Hz – 52,0 Hz	50,2 Hz
Lower voltage			50 % U _n – 100 % U _n	85 % U _n
Upper voltage			100 % U _n – 120 % U _n	110 % U _n
Observation time			10 s – 600 s	60 s
Active power increase gradient			6 % – 3000 %/min	10 % /min
4.10.3 Starting to generate electrical power	Lower frequency		47,0 Hz – 50,0 Hz	49,5 Hz
	Upper frequency		50,0 Hz – 52,0 Hz	50,1 Hz
	Lower voltage		50 % U _n – 100 % U _n	85 % U _n
	Upper voltage		100 % U _n – 120 % U _n	110 % U _n
	Observation time		10 s – 600 s	60 s
	Active power increase gradient		6 % – 3000 %/min	disabled
4.11.1 Ceasing active power	activation option		Wi-Fi	
4.11.2 Reduction of active power on set point	activation option		Wi-Fi	
4.12 Remote information exchange	available communication standards		N/A	

^a If additional parameters have been evaluated during the test, these shall be added as additional lines in the table.
^b This column should be used for manufacturer specific parameter descriptions.